

**DTI - 7644707 - 10X10 COLOUR DOT ANTHRACITE R10B - Wet Sliptest
KO190319-2**

19 Mar 2019

Slip Resistance Classification of New Pedestrian Surfaces - AS4586:2013 Appendix A

Date Tested:	19 Mar 2019
Test Report Number:	KO190319-2
Client Name & Address:	DTI - 485 Zillmere Road ZILLMERE QLD 4034
Test Site / Project:	DTI Warehouse
Surface / Product Tested:	7644707 - 10X10 COLOUR DOT ANTHRACITE R10B - Mounted & Grouted to MDF Board
Wet Pendulum Test carried out using :	Slider 96 (4S) Rubber slider
Record ambient temperature (°C)	28
Testing Officer :	Kathryn Ording - Munro-Stanley Portable Skid Tester #1133 - 30.08.17
Testing Officer Signature	

Test Results :

Sample No.	Swing 1	Swing 2	Swing 3	Swing 4	Swing 5	Mean BPN of last 3 swings :	Surface Picture
Area 1	50	50	50	50	50	50	
Area 2	46	45	45	45	45	45	
Area 3	46	46	46	45	45	45	
Area 4	46	46	46	46	46	46	
Area 5	46	46	45	45	45	45	

Mean BPN Slip Resistance Value (SRV)

46

CLASSIFICATION using Slider 96 (4S Slider)

P4 = 45 - 54

Accredited for Compliance with ISO/IEC 17025. The information presented herein and on the Sliptest Report is copyright and is protected by copyright law, any reproduction of this information and test report except in full is prohibited. Sliptest Australia Pty. Ltd. performed this on site test with reference to the following Australian Standard testing criteria, of AS 4586:2013 Classification of new pedestrian surface materials. Appendix A – Wet Pendulum Test Method and Hand Book HB 198: 2014 with reference to AS/NZS 4663: 2004 Slip Resistance measurement of existing pedestrian surfaces and HB 197: 1999. These results to not account for Future Wear, Maintenance or Contamination of this surface once in-situ.

Page 1 of 1 - END OF REPORT