

**Lockhart Tile Traders Pty Ltd - 20x20cm Dotti Dark Grey R10A - Wet Sliptest
MO071122-19**

07 Nov 2022

Slip Resistance Classification of New Pedestrian Surfaces - AS4586:2013 Appendix A

Date Tested:	07 Nov 2022
Test Report Number:	MO071122-19
Client Name & Billing Address:	Lockhart Tile Traders Pty Ltd - 485 Zillmere Rd, Zillmere QLD 4034
Surface Tested : (Samples and Test Information Supplied by Client)	20x20cm Dotti Dark Grey R10A
Wet Pendulum Test carried out using :	Slider 96 (4S) Rubber slider
Testing Officer / Approved Signatory:	Mitchell Ording
Pendulum in use - Calibration Date :	#2140 - Munro-Stanley Portable Skid Tester (C : 26.08.2021)
Signature of Approved Signatory :	

Test Results :

Sample No.	Swing 1	Swing 2	Swing 3	Swing 4	Swing 5	Mean BPN of last 3 swings :	SCV :	Surface Picture
Sample 1	44	43	41	40	40	40	N/A	
Sample 2	40	40	40	40	40	40	N/A	
Sample 3	40	40	39	39	39	39	N/A	
Sample 4	40	40	40	39	38	39	N/A	
Sample 5	41	41	40	40	40	40	N/A	

Reported SRV For Test Area :	40
CLASSIFICATION using Slider 96 (4S Slider)	P3 = 35 - 44

Accredited for Compliance with ISO/IEC 17025. The information presented herein and on the Sliptest Report is copyright and is protected by copyright law, any reproduction of this information and test report except in full is prohibited. Sliptest Australia Pty. Ltd. performed this on site test with reference to the following Australian Standard testing criteria, of AS 4586:2013 Classification of new pedestrian surface materials. Appendix A - Wet Pendulum Test Method and Hand Book HB 198: 2014 with reference to AS/NZS 4663: 2004 Slip Resistance measurement of existing pedestrian surfaces and HB 197: 1999. These results to not account for Future Wear, Maintenance or Contamination of this surface once in-situ.

Page 1 of 1 - END OF REPORT